



ASHRAE ADDENDA

Method of Test for Conformance to BACnet®

Approved by the ASHRAE Standards Committee on June 26, 2010; by the ASHRAE Board of Directors on June 30, 2010; and by the American National Standards Institute on July 1, 2010.

This addendum was approved by a Standing Standard Project Committee (SSPC) for which the Standards Committee has established a documented program for regular publication of addenda or revisions, including procedures for timely, documented, consensus action on requests for change to any part of the standard. The change submittal form, instructions, and deadlines may be obtained in electronic form from the ASHRAE Web site (www.ashrae.org) or in paper form from the Manager of Standards.

The latest edition of an ASHRAE Standard may be purchased on the ASHRAE Web site (www.ashrae.org) or from ASHRAE Customer Service, 1791 Tullie Circle, NE, Atlanta, GA 30329-2305. E-mail: orders@ashrae.org. Fax: 404-321-5478. Telephone: 404-636-8400 (worldwide), or toll free 1-800-527-4723 (for orders in US and Canada). For reprint permission, go to www.ashrae.org/permissions.

© Copyright 2010 American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc.

ISSN 1041-2336



**American Society of Heating, Refrigerating
and Air-Conditioning Engineers, Inc.**
1791 Tullie Circle NE, Atlanta, GA 30329
www.ashrae.org

ASHRAE Standing Standard Project Committee 135
Cognizant TC: TC 1.4, Control Theory Application
SPLS Liaison: Douglas T. Reindl

David Robin, <i>Chair*</i>	Craig P. Gemmill	Carl J. Ruther
Carl Neilson, <i>Vice-Chair</i>	Daniel P. Giorgis	David G. Shike
Bernhard Isler, <i>Secretary*</i>	David G. Holmberg	Ted Sunderland
Donald P. Alexander*	Robert L. Johnson	William O. Swan, III
Barry B. Bridges*	Stephen Karg*	David B. Thompson*
Coleman L. Brumley, Jr.*	Simon Lemaire	Daniel A. Traill
Ernest C. Bryant	J. Damian Ljungquist*	Stephen J. Treado*
James F. Butler	James G. Luth	J. Michael Whitcomb*
A. J. Capowski	John J. Lynch	David F. White
Sharon E. Dinges*		

*Denotes members of voting status when the document was approved for publication.

ASHRAE STANDARDS COMMITTEE 2009–2010

Steven T. Bushby, <i>Chair</i>	Merle F. McBride
H. Michael Newman, <i>Vice-Chair</i>	Frank Myers
Robert G. Baker	Janice C. Peterson
Michael F. Beda	Douglas T. Reindl
Hoy R. Bohanon, Jr.	Lawrence J. Schoen
Kenneth W. Cooper	Boggarm S. Setty
K. William Dean	Bohd R. Subherwal
Martin Dieryckx	James R. Tauby
Allan B. Fraser	James K. Vallort
Katherine G. Hammack	William F. Walter
Nadar R. Jayaraman	Michael W. Woodford
Byron W. Jones	Craig P. Wray
Jay A. Kohler	Wayne R. Reedy, <i>BOD ExO</i>
Carol E. Marriott	Thomas E. Watson, <i>CO</i>

Stephanie Reiniche, *Manager of Standards*

SPECIAL NOTE

This American National Standard (ANS) is a national voluntary consensus standard developed under the auspices of the American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE). *Consensus* is defined by the American National Standards Institute (ANSI), of which ASHRAE is a member and which has approved this standard as an ANS, as “substantial agreement reached by directly and materially affected interest categories. This signifies the concurrence of more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that an effort be made toward their resolution.” Compliance with this standard is voluntary until and unless a legal jurisdiction makes compliance mandatory through legislation.

ASHRAE obtains consensus through participation of its national and international members, associated societies, and public review.

ASHRAE Standards are prepared by a Project Committee appointed specifically for the purpose of writing the Standard. The Project Committee Chair and Vice-Chair must be members of ASHRAE; while other committee members may or may not be ASHRAE members, all must be technically qualified in the subject area of the Standard. Every effort is made to balance the concerned interests on all Project Committees.

The Assistant Director of Technology for Standards and Special Projects of ASHRAE should be contacted for:

- a. interpretation of the contents of this Standard,
- b. participation in the next review of the Standard,
- c. offering constructive criticism for improving the Standard, or
- d. permission to reprint portions of the Standard.

DISCLAIMER

ASHRAE uses its best efforts to promulgate Standards and Guidelines for the benefit of the public in light of available information and accepted industry practices. However, ASHRAE does not guarantee, certify, or assure the safety or performance of any products, components, or systems tested, installed, or operated in accordance with ASHRAE's Standards or Guidelines or that any tests conducted under its Standards or Guidelines will be nonhazardous or free from risk.

ASHRAE INDUSTRIAL ADVERTISING POLICY ON STANDARDS

ASHRAE Standards and Guidelines are established to assist industry and the public by offering a uniform method of testing for rating purposes, by suggesting safe practices in designing and installing equipment, by providing proper definitions of this equipment, and by providing other information that may serve to guide the industry. The creation of ASHRAE Standards and Guidelines is determined by the need for them, and conformance to them is completely voluntary.

In referring to this Standard or Guideline and in marking of equipment and in advertising, no claim shall be made, either stated or implied, that the product has been approved by ASHRAE.

[This foreword and the “rationales” on the following pages are not part of this standard. They are merely informative and do not contain requirements necessary for conformance to the standard.]

FOREWORD

Addendum 135.1*d* to ANSI/ASHRAE Standard 135-2009 contains a number of changes to the current standard. These modifications are the result of change proposals made pursuant to the ASHRAE continuous maintenance procedures and of deliberations within Standing Standard Project Committee 135. The changes are summarized below.

135.1-2009*d*-1. Add test to verify that COV subscription lifetimes are not affected by time-sync requests, p.2.

135.1-2009*d*-2. Add new Active_COV_Subscription tests, p. 4.

In the following document, language added to existing clauses of ANSI/ASHRAE 135.1-2009 and addenda is indicated through the use of *italics*, while deletions are indicated by ~~strike through~~. Where entirely new subclauses are added, plain type is used throughout.

135.1-2009d-1. Add test to verify that COV subscription lifetimes are not affected by time-sync requests.

Rationale

A test is required to verify that a COV subscription's lifetime is not affected by changing the time in a device via TimeSynchronization-Request or UTCTimeSynchronization-Request.

Addendum 135.1-2009d-1

[Add new Clause 9.10.X, p. 219.]

9.10.X Ensuring Subscription Lifetimes Are Not Affected By Time Changes

Dependencies: TimeSynchronization Service Execution Tests, 9.30; UTCTimeSynchronization Service Execution Tests, 9.31.

Purpose: To verify that the IUT correctly responds to a SubscribeCOV request to establish a subscription with a temporary lifetime and that the lifetime is not affected by TimeSynchronization or UTC-TimeSynchronization service requests.

Test Concept: The TD subscribes to an object that supports COV reporting in the IUT. The time is changed to D_1 , which is more than 300 seconds in the future or the past. The object is made to change such that a COV notification would be generated and it is verified that a COV notification is issued. The subscription is then allowed to expire and the object is changed again such that a COV notification would be generated, if a subscription were present. It is verified that no notification is generated.

Test Configuration: The IUT contains an object that supports COV reporting. If the IUT does not support TimeSynchronization or UTC-TimeSynchronization, then this test shall be omitted.

1. TRANSMIT SubscribeCOV-Request,
 - 'Subscriber Process Identifier' = (any valid process identifier),
 - 'Monitored Object Identifier' = (any object supporting COV notifications),
 - 'Issue Confirmed Notifications' = TRUE | FALSE,
 - 'Lifetime' = (a value between 60 seconds and 300 seconds)
2. RECEIVE BACnet-SimpleACK-PDU
3. BEFORE **Notification Fail Time**
 - IF (the subscription was for confirmed notifications) THEN
 - RECEIVE ConfirmedCOVNotification-Request,
 - 'Subscriber Process Identifier' = (the same identifier used in the subscription),
 - 'Initiating Device Identifier' = IUT,
 - 'Monitored Object Identifier' = (the same object used in the subscription),
 - 'Time Remaining' = (the requested subscription lifetime),
 - 'List of Values' = (values appropriate to the object type of the monitored object)
 - TRANSMIT BACnet-SimpleACK-PDU
 - ELSE
 - RECEIVE UnconfirmedCOVNotification-Request,
 - 'Subscriber Process Identifier' = (the same identifier used in the subscription),
 - 'Initiating Device Identifier' = IUT,
 - 'Monitored Object Identifier' = (the same object used in the subscription),
 - 'Time Remaining' = (the requested subscription lifetime),
 - 'List of Values' = (values appropriate to the object type of the monitored object)
4. MAKE (a change to the monitored object that should cause a COV notification)
5. BEFORE **NotificationFailTime**
 - IF (the subscription was for confirmed notifications) THEN
 - RECEIVE ConfirmedCOVNotification-Request,
 - 'Subscriber Process Identifier' = (the same identifier used in the subscription),

- 'Initiating Device Identifier' = IUT,
 'Monitored Object Identifier' = (the same object used in the subscription),
 'Time Remaining' = (a value greater than 0 and less than the requested subscription lifetime),
 'List of Values' = (values appropriate to the object type of the monitored object)
 TRANSMIT BACnet-SimpleACK-PDU
- ELSE
 RECEIVE UnconfirmedCOVNotification-Request,
 'Subscriber Process Identifier' = (the same identifier used in the subscription),
 'Initiating Device Identifier' = IUT,
 'Monitored Object Identifier' = (the same object used in the subscription),
 'Time Remaining' = (a value greater than 0 and less than the requested subscription lifetime),
 'List of Values' = (values appropriate to the object type of the monitored object including the changed value of that triggered the notification)
6. TRANSMIT
 DA = GLOBAL BROADCAST,
 SA = TD,
 BACnet-Unconfirmed-Request-PDU,
 'Service Choice' = TimeSynchronization-Request,
 date = D₁,
 time = D₁
7. TRANSMIT
 DA = GLOBAL BROADCAST,
 SA = TD,
 BACnet-Unconfirmed-Request-PDU,
 'Service Choice' = UTC-TimeSynchronization-Request,
 date = D₁,
 time = D₁
8. MAKE (a change to the monitored object that should cause a COV notification)
9. BEFORE **NotificationFailTime**
 IF (the subscription was for confirmed notifications) THEN
 RECEIVE ConfirmedCOVNotification-Request,
 'Subscriber Process Identifier' = (the same identifier used in the subscription),
 'Initiating Device Identifier' = IUT,
 'Monitored Object Identifier' = (the same object used in the subscription),
 'Time Remaining' = (a value greater than 0 and less than the requested subscription lifetime),
 'List of Values' = (values appropriate to the object type of the monitored object)
 TRANSMIT BACnet-SimpleACK-PDU
- ELSE
 RECEIVE UnconfirmedCOVNotification-Request,
 'Subscriber Process Identifier' = (the same identifier used in the subscription),
 'Initiating Device Identifier' = IUT,
 'Monitored Object Identifier' = (the same object used in the subscription),
 'Time Remaining' = (a value greater than 0 and less than the requested subscription lifetime),
 'List of Values' = (values appropriate to the object type of the monitored object including the changed value of that triggered the notification)
10. WAIT (the remaining lifetime of the subscription)
11. MAKE (a change to the monitored object that would cause a COV notification if there were an active subscription)
12. CHECK (verify that the IUT did not transmit a COV notification message)

135.1-2009d-2. Add new Active_COV_Subscription tests.

Rationale

There are currently no tests in Standard 135.1-2009 to test the functionality of the Active_COV_Subscriptions property, but tests for this functionality are needed.

Addendum 135.1-2009d-2

[Change Clause 7.3.2.10, p. 63]

7.3.2.10 Device Object ~~Test~~Tests

All necessary tests for functionality of the Device object are covered by tests for the application service or special functionality to which they correspond. The following tests cover cases that are not covered elsewhere.

[Add new Clause 7.3.2.10.1, p. 63]

7.3.2.10.1 Active_COV_Subscriptions SubscribeCOV Test

Purpose: This test case verifies that the IUT correctly updates the Active_COV_Subscriptions property when COV subscriptions are created, cancelled and timed-out using SubscribeCOV.

Configuration Requirements: In this test, the tester shall choose three standard objects, O₁, O₂, and O₃, for which the device supports SubscribeCOV. O₁, O₂, and O₃ are not required to refer to different objects. The tester shall also choose three non-zero unique process identifiers, P₁, P₂, and P₃, and three non-zero lifetimes L₁, L₂ and L₃. Lifetime L₁ shall be long enough to allow the initial part of the test to run through to step 14. Lifetimes L₂ and L₃ shall be long enough for the whole test to be completed without expiring.

The IUT shall start the test with no entries in its Active_COV_Subscriptions property.

Test Steps:

1. TRANSMIT SubscribeCOV-Request,
 'Subscriber Process Identifier' = P₁,
 'Monitored Object Identifier' = O₁,
 'Issue Confirmed Notifications' = TRUE,
 'Lifetime' = L₁
2. RECEIVE BACnet-SimpleACK-PDU
3. BEFORE **NotificationFailTime**
 RECEIVE ConfirmedCOVNotification-Request,
 'Subscriber Process Identifier' = P₁,
 'Initiating Device Identifier' = IUT,
 'Monitored Object Identifier' = O₁,
 'Time Remaining' = (a value approximately equal to L₁),
 'List of Values' = (values appropriate to the object type of the monitored object)
4. TRANSMIT BACnet-SimpleACK-PDU
5. VERIFY Active_COV_Subscriptions = { { {TD, P₁}, {O₁, Present_Value }, TRUE, (a value less than L₁), (a valid Increment if the property is REAL) } }
6. TRANSMIT SubscribeCOV-Request,
 'Subscriber Process Identifier' = P₂,
 'Monitored Object Identifier' = O₂,
 'Issue Confirmed Notifications' = FALSE,
 'Lifetime' = L₂
7. RECEIVE BACnet-SimpleACK-PDU
8. BEFORE **NotificationFailTime**
 RECEIVE UnconfirmedCOVNotification-Request,

- 'Subscriber Process Identifier' = P₂,
 'Initiating Device Identifier' = IUT,
 'Monitored Object Identifier' = O₂,
 'Time Remaining' = (a value approximately equal to L₂),
 'List of Values' = (values appropriate to the object type of the monitored object)
9. VERIFY Active_COV_Subscriptions = { { {TD, P₁}, {O₁, Present_Value}, TRUE, (a value less than L₁), (a valid Increment if the property is REAL) }, { {TD, P₂}, {O₂, Present_Value}, FALSE, (a value less than L₂), (a valid Increment if the property is REAL) } }
10. TRANSMIT SubscribeCOV-Request,
 'Subscriber Process Identifier' = P₃,
 'Monitored Object Identifier' = O₃,
 'Issue Confirmed Notifications' = FALSE,
 'Lifetime' = L₃
11. RECEIVE BACnet-SimpleACK-PDU
12. BEFORE **NotificationFailTime**
 RECEIVE UnconfirmedCOVNotification-Request,
 'Subscriber Process Identifier' = P₃,
 'Initiating Device Identifier' = IUT,
 'Monitored Object Identifier' = O₃,
 'Time Remaining' = (a value approximately equal to L₃),
 'List of Values' = (values appropriate to the object type of the monitored object)
13. VERIFY Active_COV_Subscriptions = { { {TD, P₁}, {O₁, Present_Value}, TRUE, (a value less than L₁), (a valid Increment if the property is REAL) }, { {TD, P₂}, {O₂, Present_Value}, FALSE, (a value less than L₂), (a valid Increment if the property is REAL) }, { {TD, P₃}, {O₃, Present_Value}, FALSE, (a value less than L₃), (a valid Increment if the property is REAL) } }
14. WAIT L₁ + the IUT's timer granularity
15. VERIFY Active_COV_Subscriptions = { { {TD, P₂}, {O₂, Present_Value}, FALSE, (a value less than L₂), (a valid Increment if the property is REAL) }, { {TD, P₃}, {O₃, Present_Value}, FALSE, (a value less than L₃), (a valid Increment if the property is REAL) } }
16. TRANSMIT SubscribeCOV-Request,
 'Subscriber Process Identifier' = P₃,
 'Monitored Object Identifier' = O₃
17. RECEIVE BACnet-SimpleACK-PDU
18. VERIFY Active_COV_Subscriptions = { { {TD, P₂}, {O₂, Present_Value}, FALSE, (a value less than L₂), (a valid Increment if the property is REAL) } }
19. TRANSMIT SubscribeCOV-Request,
 'Subscriber Process Identifier' = P₂,
 'Monitored Object Identifier' = O₂
20. RECEIVE BACnet-SimpleACK-PDU
21. VERIFY Active_COV_Subscriptions = { }

[Add new Clause 7.3.2.10.2, p. 63]

7.3.2.10.2 Active_COV_Subscriptions SubscribeCOVProperty Test

Purpose: This test case verifies that the IUT correctly updates the Active_COV_Subscriptions property when COV subscriptions are created, cancelled and timed-out using SubscribeCOVProperty.

Configuration Requirements: In this test, the tester shall choose three objects and properties, O₁, O₂, and O₃, for which the device supports SubscribeCOVProperty. O₁, O₂, and O₃ are not required to refer to different objects. The tester shall also choose three non-zero unique process identifiers, P₁, P₂, and P₃, and three non-zero lifetimes, L₁, L₂ and L₃. Lifetime

L₁ shall be long enough to allow the initial part of the test to run through to step 14. Lifetimes L₂ and L₃ shall be long enough for the whole test to be completed without expiring.

Test Steps: The test steps for this test case are identical to the test steps in Clause 7.3.2.10.1 except that `SubscribeCOVProperty` is used instead of `SubscribeCOV` and the `Active_COV_Subscriptions` entries shall reflect the property actually subscribed to (and not `Present_Value` if the subscribed property is not `Present_Value`).

[Add a new entry to **History of Revisions**, p. 489]

(This History of Revisions is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard.)

HISTORY OF REVISIONS

<i>Summary of Changes to the Standard</i>
...
Addendum d to ANSI/ASHRAE 135.1-2009 Approved by the ASHRAE Standards Committee June 26, 2010 ; by the ASHRAE Board of Directors June 30, 2010 ; and by the American National Standards Institute July 1, 2010 .
<ol style="list-style-type: none">1. Add test to verify that COV subscription lifetimes are not affected by time-sync requests.2. Add new <code>Active_COV_Subscription</code> tests.

**POLICY STATEMENT DEFINING ASHRAE'S CONCERN
FOR THE ENVIRONMENTAL IMPACT OF ITS ACTIVITIES**

ASHRAE is concerned with the impact of its members' activities on both the indoor and outdoor environment. ASHRAE's members will strive to minimize any possible deleterious effect on the indoor and outdoor environment of the systems and components in their responsibility while maximizing the beneficial effects these systems provide, consistent with accepted standards and the practical state of the art.

ASHRAE's short-range goal is to ensure that the systems and components within its scope do not impact the indoor and outdoor environment to a greater extent than specified by the standards and guidelines as established by itself and other responsible bodies.

As an ongoing goal, ASHRAE will, through its Standards Committee and extensive technical committee structure, continue to generate up-to-date standards and guidelines where appropriate and adopt, recommend, and promote those new and revised standards developed by other responsible organizations.

Through its *Handbook*, appropriate chapters will contain up-to-date standards and design considerations as the material is systematically revised.

ASHRAE will take the lead with respect to dissemination of environmental information of its primary interest and will seek out and disseminate information from other responsible organizations that is pertinent, as guides to updating standards and guidelines.

The effects of the design and selection of equipment and systems will be considered within the scope of the system's intended use and expected misuse. The disposal of hazardous materials, if any, will also be considered.

ASHRAE's primary concern for environmental impact will be at the site where equipment within ASHRAE's scope operates. However, energy source selection and the possible environmental impact due to the energy source and energy transportation will be considered where possible. Recommendations concerning energy source selection should be made by its members.

