

ANSI/ASHRAE Addendum h  
to ANSI/ASHRAE Standard 135-2008



# ASHRAE STANDARD

## BACnet<sup>®</sup> — A Data Communication Protocol for Building Automation and Control Networks

Approved by the ASHRAE Standards Committee on January 23, 2010; by the ASHRAE Board of Directors on January 27, 2010; and by the American National Standards Institute on January 28, 2010.

This standard is under continuous maintenance by a Standing Standard Project Committee (SSPC) for which the Standards Committee has established a documented program for regular publication of addenda or revisions, including procedures for timely, documented, consensus action on requests for change to any part of the standard. The change submittal form, instructions, and deadlines may be obtained in electronic form from the ASHRAE Web site, <http://www.ashrae.org>, or in paper form from the Manager of Standards. The latest edition of an ASHRAE Standard may be purchased from ASHRAE Customer Service, 1791 Tullie Circle, NE, Atlanta, GA 30329-2305. E-mail: [orders@ashrae.org](mailto:orders@ashrae.org). Fax: 404-321-5478. Telephone: 404-636-8400 (worldwide), or toll free 1-800-527-4723 (for orders in US and Canada).

© Copyright 2010 American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc.

ISSN 1041-2336



**American Society of Heating, Refrigerating  
and Air-Conditioning Engineers, Inc.**  
1791 Tullie Circle NE, Atlanta, GA 30329  
[www.ashrae.org](http://www.ashrae.org)

**ASHRAE Standing Standard Project Committee 135**  
**Cognizant TC: TC 1.4, Control Theory and Application**  
**SPLS Liaison: Douglas T. Reindl**

David Robin, <i>Chair*</i>	Troy Cowan	John J. Lynch
Carl Neilson, <i>Vice-Chair</i>	Thomas Ertsgaard	Mark A. Railsback
Sharon E. Dinges, <i>Secretary*</i>	Craig P. Gemmill	Carl J. Ruthr
Donald P. Alexander*	Daniel P. Giorgis	David G. Shike
David J. Branson	Ira G. Goldschmidt	Ted Sunderland
Barry B. Bridges*	David G. Holmberg	William O. Swan, III
Coleman L. Brumley, Jr.*	Bernhard Isler*	David B. Thompson*
Ernest C. Bryant	Robert L. Johnson	Daniel A Traill
Steven T. Bushby	Stephen Karg*	Stephen J. Treado*
James F. Butler	Simon Lemaire	J . Michael Whitcomb*
A.J. Capowski	J. Damian Ljungquist*	David F. White
	James G. Luth	

\*Denotes members of voting status when the document was approved for publication

---

**ASHRAE STANDARDS COMMITTEE 2009–2010**

Steven T. Bushby, <i>Chair</i>	Merle F. McBride
H. Michael Newman, <i>Vice-Chair</i>	Frank Myers
Robert G. Baker	Janice C. Peterson
Michael F. Beda	Douglas T. Reindl
Hoy R. Bohanon, Jr.	Lawrence J. Schoen
Kenneth W. Cooper	Boggarm S. Setty
K. William Dean	Bodh R. Subherwal
Martin Dieryckx	James R. Tauby
Allan B. Fraser	James K. Vallort
Katherine G. Hammack	William F. Walter
Nadar R. Jayaraman	Michael W. Woodford
Byron W. Jones	Craig P. Wray
Jay A. Kohler	Wayne R. Reedy, <i>BOD ExO</i>
Carol E. Marriott	Thomas E. Watson, <i>CO</i>

Stephanie Reiniche, *Manager of Standards*

---

**SPECIAL NOTE**

This American National Standard (ANS) is a national voluntary consensus standard developed under the auspices of the American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE). *Consensus* is defined by the American National Standards Institute (ANSI), of which ASHRAE is a member and which has approved this standard as an ANS, as “substantial agreement reached by directly and materially affected interest categories. This signifies the concurrence of more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that an effort be made toward their resolution.” Compliance with this standard is voluntary until and unless a legal jurisdiction makes compliance mandatory through legislation.

ASHRAE obtains consensus through participation of its national and international members, associated societies, and public review.

ASHRAE Standards are prepared by a Project Committee appointed specifically for the purpose of writing the Standard. The Project Committee Chair and Vice-Chair must be members of ASHRAE; while other committee members may or may not be ASHRAE members, all must be technically qualified in the subject area of the Standard. Every effort is made to balance the concerned interests on all Project Committees.

The Manager of Standards of ASHRAE should be contacted for:

- a. interpretation of the contents of this Standard,
- b. participation in the next review of the Standard,
- c. offering constructive criticism for improving the Standard, or
- d. permission to reprint portions of the Standard.

**DISCLAIMER**

ASHRAE uses its best efforts to promulgate Standards and Guidelines for the benefit of the public in light of available information and accepted industry practices. However, ASHRAE does not guarantee, certify, or assure the safety or performance of any products, components, or systems tested, installed, or operated in accordance with ASHRAE’s Standards or Guidelines or that any tests conducted under its Standards or Guidelines will be nonhazardous or free from risk.

**ASHRAE INDUSTRIAL ADVERTISING POLICY ON STANDARDS**

ASHRAE Standards and Guidelines are established to assist industry and the public by offering a uniform method of testing for rating purposes, by suggesting safe practices in designing and installing equipment, by providing proper definitions of this equipment, and by providing other information that may serve to guide the industry. The creation of ASHRAE Standards and Guidelines is determined by the need for them, and conformance to them is completely voluntary.

In referring to this Standard or Guideline and in marking of equipment and in advertising, no claim shall be made, either stated or implied, that the product has been approved by ASHRAE.

**[This foreword and the “rationales” on the following pages are not part of this standard. They are merely informative and do not contain requirements necessary for conformance to the standard.]**

## FOREWORD

Addendum 135*h* to ANSI/ASHRAE Standard 135-2008 contains a number of changes to the current standard. These modifications are the result of change proposals made pursuant to the ASHRAE continuous maintenance procedures and of deliberations within Standing Standard Project Committee 135. The changes are summarized below.

- 135-2008*h*-1. Change Device\_Busy to Busy and apply to the Command Object type, p. 2.**
- 135-2008*h*-2. Prevent overflow and underflow in Pulse\_Converter object's Count property, p. 3.**
- 135-2008*h*-3. Add context tags to Clause 21 production BACnetPropertyStates, p. 4.**
- 135-2008*h*-4. Add new BACnetEngineering Units, p. 5.**
- 135-2008*h*-5. Define COV notification service Error returns, p. 6.**
- 135-2008*h*-6. Remove non-support for automatic cancellation of COV subscriptions, p. 8.**
- 135-2008*h*-7. [This section removed from this addendum]**
- 135-2008*h*-8. Add even and odd day support in Dates, p. 10.**

In the following document, language added to existing clauses of ANSI/ASHRAE 135-2008 and addenda is indicated through the use of *italics*, while deletions are indicated by ~~strike through~~. Where entirely new subclauses are added, plain type is used throughout.

**135-2008h-1. Add a new BUSY Error Code and apply to the Command Object type.**

**Rationale**

The Command object is required to reject a write request to its Present\_Value property when its In\_Process property has the value BUSY, but none of the currently available error codes are exactly appropriate to the situation. A new error code, BUSY, is defined for this purpose.

**Addendum 135-2008h-1**

[Change Clause **12.10**, Command Object type, paragraph 3, p.176]

**12.10 Command Object type**

...

The Command object defines the relationship between a given state and those values that shall be written to a collection of different objects' properties to realize that state. Normally, a Command object is passive. Its In\_Process property is FALSE, indicating that the Command object is waiting for its Present\_Value property to be written with a value. When Present\_Value is written, the Command object shall begin a sequence of actions. The In\_Process property shall be set to TRUE, indicating that the Command object has begun processing one of a set of action sequences that is selected based on the particular value written to the Present\_Value property. If an attempt is made to write to the Present\_Value property through WriteProperty services while In\_Process is TRUE, then a Result(-) ~~shall be issued~~ shall be returned with 'error class' = OBJECT and 'error code' = BUSY, rejecting the write.

[Add new Clause **18.2.X**, p.391]

**18.2.X BUSY** - A service request has been temporarily declined because the addressed object is involved in a process that precludes execution of the service.

[Change Clause **21**, production , p.445]

```
Error ::= SEQUENCE {
  ...
  error-code  ENUMERATED {
    other                (0),
    ...
    authentication-failed (1),
    busy                 (82),
    character-set-not-supported (41),
    ...
  }
}
```

## 135-2008h-2. Prevent overflow and underflow in Pulse\_Converter object's Count property.

### Rationale

Currently Adjust\_Value (datatype REAL) can be successfully written with values that can cause either overflow or underflow of the Pulse Converter object's Count property (datatype Unsigned), resulting in erroneous values in the Count property.

### Addendum 135-2008h-2

[Change Clause 12.23.13, p. 240]

#### 12.23.13 Adjust\_Value

This property, of type REAL, is written to adjust the Present\_Value property (and thus the Count property also) by the amount written to Adjust\_Value.

~~If this property is writable the~~The following series of operations shall be performed atomically when this property is written:

- (1) The value written to Adjust\_Value shall be stored in the Adjust\_Value property.
- (2) The value of Count shall be copied to the Count\_Before\_Change property.
- (3) The value of Count shall be decremented by the value calculated by performing the integer division (Adjust\_Value/Scale\_Factor) and discarding the remainder.
- (4) The current date and time shall be stored in the Count\_Change\_Time property.

A write to this property results in a change in the value of Present\_Value. Whether the new value is computed as part of the atomic series of operations or when Present\_Value is read is a local matter.

*An attempt to write Adjust\_Value with a value that would cause an overflow or underflow condition in Count shall result in a Result(-) to be returned with an error class of PROPERTY and an error code of VALUE\_OUT\_OF\_RANGE.*

If Adjust\_Value has never been written, it shall have a value of zero.

### 135-2008h-3. Add context tags to Clause 21 production BACnetPropertyStates.

#### Rationale

The standard defines context tag declarations for each BACnet defined enumeration explicitly in production BACnetPropertyStates, Clause 21. Several of the BACnet defined enumeration datatypes lack these context tag declarations, so they are added here.

#### Addendum 135-2008h-3

[Change **Clause 21**, production **BACnetPropertyStates**, p. 471]

```
BACnetPropertyStates ::= CHOICE {  
  -- This production represents the possible datatypes for properties that  
  -- have discrete or enumerated values. The choice must be consistent with the  
  -- datatype of the property referenced in the Event Enrollment Object.  
  
  boolean-value      [0] BOOLEAN,  
  ...  
  door-alarm-state   [15] BACnetDoorAlarmState  
  action              [16] BACnetAction,  
  door-secured-status [17] BACnetDoorSecuredStatus,  
  door-status        [18] BACnetDoorStatus,  
  door-value         [19] BACnetDoorValue,  
  file-access-method [20] BACnetFileAccessMethod,  
  lock-status        [21] BACnetLockStatus,  
  life-safety-operation [22] BACnetLifeSafetyOperation,  
  maintenance        [23] BACnetMaintenance,  
  node-type          [24] BACnetNodeType,  
  notify-type        [25] BACnetNotifyType,  
  security-level     [26] BACnetSecurityLevel,  
  shed-state         [27] BACnetShedState,  
  silenced-state     [28] BACnetSilencedState  
  ...  
}
```

#### 135-2008h-4. Add new BACnetEngineering Units.

##### Rationale

Requests were made from several sources for support for three additional engineering units, which are added here.

##### Addendum 135-2008h-4

[Change Clause 21, BACnetEngineeringUnits production, p. 451]

**BACnetEngineeringUnits** ::= {

...

--Electrical

...

megohms	(123),
<i>micro-siemens</i>	(190),
siemens	(173), -- 1 mho equals 1 siemens

...

--Volumetric Flow

cubic-feet-per-second	(142),
cubic-feet-per-minute	(84),
<i>cubic-feet-per-hour</i>	(191),
cubic-meters-per-second	(85),

...

liters-per-hour	(136),
<i>us-gallons-per-hour</i>	(192),
us-gallons-per-minute	(89),

...

... The last enumeration used in this version is 189.

**135-2008h-5 Define COV notification service Error returns.**

**Rationale**  
 Standard 135.1 defines Error returns for the ConfirmedCOVNotification service that are not required by the current edition of Standard 135; those Error returns are specified here for Standard 135.

**Addendum 135-2008h-5**

[Change Clause **13.6.2**, p. 309, ConfirmedCOVNotification service procedure]

**13.6.2 Service Procedure**

After verifying the validity of the request, the responding BACnet-user shall take whatever local actions have been assigned to the indicated COV and issue a 'Result(+)' service primitive. If the service request cannot be executed, a 'Result(-)' service primitive shall be issued indicating the error encountered.

*The 'Error Class' and 'Error Code' to be returned for specific situations are as follows:*

<i>Situation:</i>	<i>Error Class:</i>	<i>Error Code:</i>
<i>No subscription exists for the specified object, property, and process identifier. Devices may ignore this condition and return a BACnet-SimpleACK-PDU.</i>	<i>SERVICES</i>	<i>UNKNOWN_SUBSCRIPTION</i>

[Change Clause **13.14.2**, p. 326, SubscribeCOV service procedure]

**13.14.2 Service Procedure**

...  
 If a new context is created, or a re-subscription is received, then the COV context shall be initialized and given a lifetime as specified by the 'Lifetime' parameter, if present, or zero if the 'Lifetime' parameter is not present. The subscription shall be automatically cancelled after that many seconds have elapsed unless a re-subscription is received. A lifetime of zero shall indicate that the subscription is indefinite and no automatic cancellation shall occur. In either case, a 'Result(+)' shall be returned. A ConfirmedCOVNotification or UnconfirmedCOVNotification shall be issued as soon as possible after the successful completion of a subscription or re-subscription request, as specified by the 'Issue Confirmed Notifications' parameter.

*The 'Error Class' and 'Error Code' to be returned for specific situations are as follows:*

<i>Situation:</i>	<i>Error Class:</i>	<i>Error Code:</i>
<i>Specified object does not exist</i>	<i>OBJECT</i>	<i>UNKNOWN_OBJECT</i>
<i>Specified object does not support COV notifications</i>	<i>OBJECT</i>	<i>OPTIONAL_FUNCTIONALITY_NOT_SUPPORTED</i>
<i>No context can be created due to resource limitations</i>	<i>RESOURCES</i>	<i>NO_SPACE_TO_ADD_LIST_ELEMENT</i>
<i>The Lifetime parameter is out of the range supported by the device</i>	<i>SERVICES</i>	<i>VALUE_OUT_OF_RANGE</i>

[Add new Clause **18.2.X**, p. 391]

**18.2.X OPTIONAL\_FUNCTIONALITY\_NOT\_SUPPORTED** – The requested action cannot be executed because the specified object does not support the optional functionality required.

[Add new Clauses **18.6.X** and **18.6.Y**, p. 393]

**18.6.X UNKNOWN\_SUBSCRIPTION** – No subscription can be found that matches the specified object, property, and process identifier for the received notification.

**18.6.Y VALUE\_OUT\_OF\_RANGE** – The requested action cannot be executed because one of the parameters provided is outside of the range supported by the device.

[Change Clause **21, Error** production, p. 445]

```
Error ::= SEQUENCE {  
  ...  
  error-code    ENUMERATED {  
    other                (0),  
    ...  
    unknown-property    (32),  
    unknown-subscription (79),  
    -- this enumeration was removed (33),  
    unknown-vt-class     (34),  
    ...  
    -- see unknown-subscription (79),  
    ...  
}
```

### **135-2008h-6. Remove non-support for automatic cancellation of COV subscriptions.**

#### **Rationale**

The service procedure for the SubscribeCOV service states that a device is allowed to have no support for automatic cancellation of COV subscriptions. This lack of capability was deprecated, so the statement is being removed.

#### **Addendum 135-2008h-6**

[Change Clause **13.14.2**, SubscribeCOV service, p. 326]

##### **13.14.2 Service Procedure**

If neither 'Lifetime' nor 'Issue Confirmed Notifications' are present, then the request shall be considered to be a cancellation. Any COV context that already exists for the same BACnet address contained in the PDU that carries the SubscribeCOV request and has the same 'Subscriber Process Identifier' and 'Monitored Object Identifier' shall be disabled and a 'Result(+)' returned. Cancellations that are issued for which no matching COV context can be found shall succeed as if a context had existed, returning 'Result(+)'.

~~If the 'Lifetime' parameter is present and has a non-zero value but the device does not support automatic cancellation of subscriptions, then a 'Result(-)' shall be returned.~~ If the 'Lifetime' parameter is not present but the 'Issue Confirmed Notifications' parameter is present, then a value of zero (indefinite lifetime) shall be assumed for the lifetime. If the 'Issue Confirmed Notifications' parameter is present but the object to be monitored does not support COV reporting, then a 'Result(-)' shall be returned. If the object to be monitored does support COV reporting, then a check shall be made to locate an existing COV context for the same BACnet address contained in the PDU that carries the SubscribeCOV request and has the same 'Subscriber Process Identifier' and 'Monitored Object Identifier'. If an existing COV context is found, then the request shall be considered a re-subscription and shall succeed as if the subscription had been newly created.

**135-2008h-7.** [this section has been removed]

**135-2008h-8. Add even and odd day support in Dates.**

**Rationale**  
Resource conservation sometimes requires schedules to be able to turn on automated watering systems on either even- or odd-numbered days of the month. Adding enumerations to support this would facilitate automated scheduling of such operations.

**Addendum 135-2008h-8**

[Change Clause **20.2.12**, p. 422]

**20.2.12 Encoding of a Date Value**

The encoding of a date value shall be primitive, with four contents octets.

Date values shall be encoded in the contents octets as four binary integers. The first ~~contents~~ octet shall represent the year minus 1900; the second octet shall represent the month, with January = 1; the third octet shall represent the day of the month; and the fourth octet shall represent the day of the week, with Monday = 1. A value of X'FF' = D'255' in any of the four octets shall indicate that the corresponding value is unspecified. If all four octets = X'FF', the corresponding date may be interpreted as "any" or "don't care."

*A number of special values for the month and day octets have been defined. The following special values shall not be used when conveying an actual date value, such as the Local\_Date property of the Device object or in a TimeSynchronization-Request. A value of 13 in the second octet shall indicate odd months. A value of 14 in the second octet shall indicate even months. A value of 32 in the third octet shall indicate the last day of the month. A value of 33 in the third octet shall indicate odd days of the month. A value of 34 in the third octet shall indicate even days of the month.*

[Change Clause **21, Date**, p. 448]

**Date** ::= [APPLICATION 10] OCTET STRING (SIZE(4)) -- see 20.2.12  
-- first octet    year minus 1900            X'FF' = unspecified  
-- second octet   month (1..14)            1 = January  
--    13 = odd months  
--    14 = even months  
--    X'FF' = unspecified  
-- third octet    day of month (1..~~32~~34),  
--    32 = last day of month  
--    33 = odd days of month  
--    34 = even days of month  
--    X'FF' = unspecified  
-- fourth octet   day of week (1..7)        1 = Monday  
--    7 = Sunday  
--    X'FF' = unspecified

[Add a new entry to **History of Revisions**, p. 688]

**(This History of Revisions is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard.)**

**HISTORY OF REVISIONS**

<i>Protocol</i>		<i>Summary of Changes to the Standard</i>
<i>Version</i>	<i>Revision</i>	
...	...	...
1	10	<p><b>Addendum h to ANSI/ASHRAE 135-2008</b>                      Approved by the ASHRAE Standards Committee January 23, 2010; by the ASHRAE Board of Directors January 27, 2010; and by the American National Standards Institute January 28, 2010.</p> <ol style="list-style-type: none"> <li>1. Change Device_Busy to Busy and apply to the Command Object type.</li> <li>2. Prevent overflow and underflow in Pulse_Converter object's Count property.</li> <li>3. Add context tags to Clause 21 production BACnetPropertyStates.</li> <li>4. Add new BACnetEngineering Units.</li> <li>5. Define COV notification service Error returns.</li> <li>6. Remove non-support for automatic cancellation of COV subscriptions.</li> <li>7. [This section removed from this addendum]</li> <li>8. Add even and odd day support in Dates.</li> </ol>

**POLICY STATEMENT DEFINING ASHRAE'S CONCERN  
FOR THE ENVIRONMENTAL IMPACT OF ITS ACTIVITIES**

ASHRAE is concerned with the impact of its members' activities on both the indoor and outdoor environment. ASHRAE's members will strive to minimize any possible deleterious effect on the indoor and outdoor environment of the systems and components in their responsibility while maximizing the beneficial effects these systems provide, consistent with accepted standards and the practical state of the art.

ASHRAE's short-range goal is to ensure that the systems and components within its scope do not impact the indoor and outdoor environment to a greater extent than specified by the standards and guidelines as established by itself and other responsible bodies.

As an ongoing goal, ASHRAE will, through its Standards Committee and extensive technical committee structure, continue to generate up-to-date standards and guidelines where appropriate and adopt, recommend, and promote those new and revised standards developed by other responsible organizations.

Through its *Handbook*, appropriate chapters will contain up-to-date standards and design considerations as the material is systematically revised.

ASHRAE will take the lead with respect to dissemination of environmental information of its primary interest and will seek out and disseminate information from other responsible organizations that is pertinent, as guides to updating standards and guidelines.

The effects of the design and selection of equipment and systems will be considered within the scope of the system's intended use and expected misuse. The disposal of hazardous materials, if any, will also be considered.

ASHRAE's primary concern for environmental impact will be at the site where equipment within ASHRAE's scope operates. However, energy source selection and the possible environmental impact due to the energy source and energy transportation will be considered where possible. Recommendations concerning energy source selection should be made by its members.