ANSI/ASHRAE Addendum o to ANSI/ASHRAE Standard 135-2008





# BACnet<sup>®</sup>—A Data Communication Protocol for Building Automation and Control Networks

Approved by the ASHRAE Standards Committee on June 20, 2009; by the ASHRAE Board of Directors on June 24, 2009; and by the American National Standards Institute on June 25, 2009.

This standard is under continuous maintenance by a Standing Standard Project Committee (SSPC) for which the Standards Committee has established a documented program for regular publication of addenda or revisions, including procedures for timely, documented, consensus action on requests for change to any part of the standard. The change submittal form, instructions, and deadlines may be obtained in electronic form from the ASHRAE Web site, http://www.ashrae.org, or in paper form from the Manager of Standards. The latest edition of an ASHRAE Standard may be purchased from ASHRAE Customer Service, 1791 Tullie Circle, NE, Atlanta, GA 30329-2305. E-mail: orders@ashrae.org. Fax: 404-321-5478. Telephone: 404-636-8400 (worldwide), or toll free 1-800-527-4723 (for orders in US and Canada).

© Copyright 2009 American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc.

ISSN 1041-2336



American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc.

1791 Tullie Circle NE, Atlanta, GA 30329 www.ashrae.org © 2009, American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc. (www.ashrae.org). For personal use only. Additional reproduction, distribution, or transmission in either print or digital form is not permitted without ASHRAE's prior written permission.

#### ASHRAE Standing Standard Project Committee 135 Cognizant TC: TC 1.4, Control Theory and Application SPLS Liaison: Douglas T. Reindl

- David Robin, *Chair* Carl Neilson, *Vice-Chair*\* Sharon E. Dinges, *Secretary*\* Donald P. Alexander\* Barry B. Bridges\* Coleman L. Brumley, Jr.\* Ernest C. Bryant\* James F. Butler
- Craig P. Gemmill David G. Holmberg\* Bernhard Isler\* Robert L. Johnson\* Stephen Karg\* Simon Lemaire J. Damian Ljungquist\* James G. Luth\* John J. Lynch

Carl J. Ruther\* David G. Shike Ted Sunderland William O. Swan, III\* David B. Thompson\* Stephen J. Treado J. Michael Whitcomb David F. White

\*Denotes members of voting status when the document was approved for publication

#### ASHRAE STANDARDS COMMITTEE 2008-2009

Hugh F. Crowther, *Chair* Steven T. Bushby, *Vice-Chair* Robert G. Baker Michael F. Beda Donald L. Brandt Paul W. Cabot Kenneth W. Cooper Samuel D. Cummings, Jr K. William Dean Martin Dierycxk Robert G. Doerr Allan B. Fraser Nadar R. Jayaraman Byron W. Jones Jay A. Kohler Carol E. Marriott Merle F. McBride Frank Myers H. Michael Newman Janice C. Peterson Douglas T. Reindl Lawrence J. Schoen Boggarm S. Setty Bodh R. Subherwal William F. Walter Michael W. Woodford David E. Knebel, *BOD ExO* Andrew K. Persily, *CO* 

Stephanie Reiniche, Manager of Standards

#### SPECIAL NOTE

This American National Standard (ANS) is a national voluntary consensus standard developed under the auspices of the American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE). *Consensus* is defined by the American National Standards Institute (ANSI), of which ASHRAE is a member and which has approved this standard as an ANS, as "substantial agreement reached by directly and materially affected interest categories. This signifies the concurrence of more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that an effort be made toward their resolution." Compliance with this standard is voluntary until and unless a legal jurisdiction makes compliance mandatory through legislation.

ASHRAE obtains consensus through participation of its national and international members, associated societies, and public review.

ASHRAE Standards are prepared by a Project Committee appointed specifically for the purpose of writing the Standard. The Project Committee Chair and Vice-Chair must be members of ASHRAE; while other committee members may or may not be ASHRAE members, all must be technically qualified in the subject area of the Standard. Every effort is made to balance the concerned interests on all Project Committees.

The Manager of Standards of ASHRAE should be contacted for:

- a. interpretation of the contents of this Standard,
- b. participation in the next review of the Standard,
- c. offering constructive criticism for improving the Standard, or
- d. permission to reprint portions of the Standard.

#### DISCLAIMER

ASHRAE uses its best efforts to promulgate Standards and Guidelines for the benefit of the public in light of available information and accepted industry practices. However, ASHRAE does not guarantee, certify, or assure the safety or performance of any products, components, or systems tested, installed, or operated in accordance with ASHRAE's Standards or Guidelines or that any tests conducted under its Standards or Guidelines will be nonhazardous or free from risk.

#### ASHRAE INDUSTRIAL ADVERTISING POLICY ON STANDARDS

ASHRAE Standards and Guidelines are established to assist industry and the public by offering a uniform method of testing for rating purposes, by suggesting safe practices in designing and installing equipment, by providing proper definitions of this equipment, and by providing other information that may serve to guide the industry. The creation of ASHRAE Standards and Guidelines is determined by the need for them, and conformance to them is completely voluntary.

In referring to this Standard or Guideline and in marking of equipment and in advertising, no claim shall be made, either stated or implied, that the product has been approved by ASHRAE.

# [This foreword and the "rationale" on the following page are not part of this standard. They are merely informative and do not contain requirements necessary for conformance to the standard.]

### FOREWORD

Addendum 135*o* to ANSI/ASHRAE Standard 135-2008 contains a number of changes to the current standard. These modifications are the result of change proposals made pursuant to the ASHRAE continuous maintenance procedures and of deliberations within Standard Project Committee 135. The changes are summarized below.

135-2008o-1. Accommodate remote operator access and NAT in Annex J BACnet/IP, p. 2.

In the following document, language to be added to existing clauses of ANSI/ASHRAE 135-2008 and Addenda is indicated through the use of *italics*, while deletions are indicated by strikethrough. Where entirely new subclauses are added, plain type is used throughout.

SSPC 135 wishes to express its appreciation to Howard Coleman, John Hartman, Dean Matsen, Bryan Meyers and Andreas Schlumberger for the help they provided in developing this addendum.

# 135-2008o-1. Accommodate remote operator access and NAT in Annex J BACnet/IP.

Rationale

Two common uses cases for Annex J BACnet/IP are not sufficiently well accommodated by Annex J: Network Address Translation (NAT) and operator access across the Internet to multiple remote subnets. Some small changes have been implemented to accommodate these cases.

# Addendum 135-2008*o*-1

[Add new acronym to Clause 3.3, pp. 5-7, in alphabetic order.]

 NAT 	Network Address Translation – RFC 2663	
[Change AN	<b>NEX A</b> , p. 495.]	
Networking	Options:	
□ Annex H □ BACnet/ Does th	Clause 6 - List all routing configurations, e.g., ARCNE , BACnet Tunneling Router over IP IP Broadcast Management Device (BBMD) e BBMD support registrations by Foreign Devices? e BBMD support network address translation?	T-Ethernet, Ethernet-MS/TP, etc.

[Change Clause J.2.5, p. 619.]

# J.2.5 Forwarded-NPDU: Purpose

This BVLL message is used in broadcast messages from a BBMD as well as in messages forwarded to registered foreign devices. It contains the source address of the original node node, or if NAT is being used, the address with which the original node is accessed as well as the original BACnet NPDU.

[Change Clause J.4.3, p. 621.]

# J.4.3 BBMD Concept

Each IP subnet that is part of a B/IP network comprised of two or more subnets shall have one, and only one, BBMD. *at least one BBMD*. Each BBMD shall possess a table called a Broadcast Distribution Table (BDT) which shall be the same in every BBMD in a given B/IP network. (BDT). If there are two or more BBMDs on a single subnet, their BDTs shall not contain any common entries in order to avoid a broadcast forwarding loop. The BDT determines which remote IP subnets receive forwarded BACnet broadcasts. To reduce BACnet broadcast traffic, it is possible to configure the BDT to forward broadcasts only to IP subnets where they are required. If the BBMD has also been designated to register foreign devices as described below, it shall also possess a Foreign Device Table (FDT).

[Change Clause J.4.3.2, p. 622.]

### J.4.3.2 Broadcast Distribution Table Format

The BDT consists of one entry for each BBMD within a B/IP network. the address of the BBMD for the local IP subnet and an entry for the BBMD on each remote IP subnet to which broadcasts are to be forwarded. Each entry consists of the 6-octet B/IP address of the BBMD serving the IP subnet with which the BBMD is accessed and a 4-octet broadcast distribution mask. If the IP router to the subnet performs network address translation (NAT), then the BDT entry shall contain the global IP address of the IP router. The operation of BBMDs in the presence of NAT is described in J.7.2. If messages are to be distributed on the remote IP subnet using directed broadcasts, the broadcast distribution mask shall be identical to the subnet mask associated with the subnet, i.e., all 1's in the network portion of the 4-octet IP address field and

© 2009 American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc. (<u>www.ashrae.org</u>). For personal use only. Additional reproduction, distribution, or transmission in either print or digital form is not permitted without ASHRAE's prior written permission.

all 0's in the host portion. If messages are to be distributed on the remote IP subnet by sending the message directly to the remote BBMD, the broadcast distribution mask shall be all 1's. *The broadcast distribution masks referring to the same IP subnet shall be identical in each BDT*. The use of the broadcast distribution mask is described in J.4.5.

# [Change Clause J.4.5 p. 622.]

# J.4.5 BBMD Operation - Broadcast Distribution

Upon receipt of a BVLL Forwarded-NPDU message, a BBMD shall process it according to whether it was received from a peer BBMD as the result of a directed broadcast or a unicast transmission. A BBMD may ascertain the method by which Forwarded-NPDU messages will arrive by inspecting the broadcast distribution mask field in its own BDT entry since all BDTs are required to be identical. masks referring to the same subnet are required to be identical in all BBMDs. If the message arrived via directed broadcast, it was also received by the other devices on the BBMD's subnet. In this case the BBMD merely retransmits the message directly to each foreign device currently in the BBMD's Subnet. In this case, the message is sent to the devices on the BBMD's subnet using the B/IP broadcast address as well as to each foreign device currently in the BBMD's FDT. A BBMD on a subnet with no other BACnet devices (such as a NAT-supporting BBMD, see J.7.2) may omit the broadcast using the B/IP broadcast address. The method by which a BBMD determines whether or not other BACnet devices are present is a local matter.

•••

[Insert new Clause J.7.X, p. 627, and renumber subsequent clauses.]

### J.7.X BBMD Operation with Network Address Translation

Network Address Translation (NAT) is in widespread use by IP routers and firewalls to connect private subnets to the global Internet. Using NAT, multiple hosts on a subnet can access the Internet using a single public IP address. BBMD operation supporting NAT routers is optional for BBMD devices. A single BACnet device may contain several B/IP network ports, each with its own internal BBMD.

For those B/IP networks that communicate through a NAT router, there are several additional considerations:

- a) For any single B/IP network, only one device on the local side of the NAT router may be accessible from the global side. All other devices on the local side of that NAT router need to be on different BACnet networks so that they can be uniquely addressed using the BACnet network layer. The globally accessible device will contain a BACnet router to those networks. The globally accessible device may be either a BBMD or a foreign device.
- b) The NAT router at each subnet location should be configured to port forward B/IP messages to the BBMD. Port forwarding causes all messages directed to the specified port to be forwarded to a specific local address.
- c) To enable messages to traverse the Internet, the destination IP address and UDP port in all Forwarded-NPDU messages shall be the global IP address and UDP port of the destination subnet. This is facilitated by entering the global B/IP address of each BBMD in the BDT.
- d) Except when propagating a received Forwarded-NPDU message, the "B/IP Address of Originating Device" field in Forwarded-NPDU messages is the global IP address and port of the NAT Router through which the BBMD communicates. This is required so that responding devices on the remote subnet may communicate with the originating device. Received Forwarded-NPDU messages are propagated as-is to foreign devices and to the local IP subnet as defined in J.4.5
- e) A foreign device behind a NAT router should register often with a BBMD to maintain a return path through the NAT router back to the foreign device. The maximum allowed time between registrations is dependent on the NAT router, and may be 30 seconds or less.
- f) Two-hop distribution shall be used in B/IP networks that contain NAT routers, since one-hop distribution is not possible through NAT routers.

A B/IP internetwork containing NAT Routers can be configured several ways. See Figures J-X1 and J-X2 for example configurations.



**Figure J-X1.** This figure represents a B/IP internetwork that uses the Internet to connect two remote sites. The NAT devices translate global Internet IP/Port addresses into private addresses. Different networks behind NAT devices may use the same IP/Port address range as demonstrated here. Both B/IP network 2 and B/IP network 3 use locally-assigned IP addresses from the subnet 192.168.1.\* and UDP port 47808.

NAT A Configuration	
Internet IP	201.1.1.1
Forward	201.1.1.1:47809 → 192.168.1.10:47809
NAT B Configuration	
Internet IP	237.2.2.2
Forward	237.2.2.2:47809 → 192.168.1.10:47809
BR1 - BBMD/Router Configu	ration
Global IP Address	201.1.1.1:47809 (global B/IP address of NAT A)
B/IP Address Net 1	192.168.1.10:47809
BDT Net 1	201.1.1.1:47809 (global B/IP address of NAT A, self),
BD1 Net I	
	237.2.2.2:47809 (global B/IP address of NAT B)
B/IP Address Net 2	192.168.1.10:47808
BDT Net 2	192.168.1.10:47808 (self)
BR2 - BBMD/Router Configu	ration
Global IP Address	237.2.2.2:47809 (global B/IP address of NAT B)
B/IP Address Net 1	192.168.1.10:47809
BDT Net 1	237.2.2.2:47809 (global B/IP address of NAT B, self),
	201.1.1.1:47809 (global B/IP address of NAT A)
B/IP Address Net 3	192.168.1.10:47808
BDT Net 3	192.168.1.10:47808 (self)
BDT Not 5	172.100.1.10.47000 (3011)

The broadcast distribution masks in the above BDT configurations are 255.255.255.255 indicating two-hop broadcast distribution.

© 2009 American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc. (<u>www.ashrae.org</u>). For personal use only. Additional reproduction, distribution, or transmission in either print or digital form is not permitted without ASHRAE's prior written permission.



**Figure J-X2.** This figure represents a potential WAN with multiple remote sites, with BACnet being connected via a corporate intranet. In this configuration, the foreign device FD1 can connect to Network 4 using local addresses and to Networks 2 and 3 using the global IP address of the NAT routers. The foreign device FD2 can only connect to the global IP addresses on the Internet side of the NAT routers.

NAT A Configuration	
Internet IP	201.1.1.1
Forward	201.1.1.1:47809 → 192.168.1.10:47809

NAT B Configuration Internet IP Forward	237.2.2.2 237.2.2.2:47809 → 192.168.1.10:47809				
NAT C Configuration Internet IP Forward	203.3.3.3 203.3.3.3:47809 → 192.168.20.10:47809				
BR1 - BBMD/Router Configuration					
Global IP Address	201.1.1.1:47809 (global B/IP address of NAT A)				
B/IP Address Net 1	192.168.1.10:47809				
BDT Net 1	201.1.1.1:47809 (global B/IP address of NAT A, self),				
	237.2.2.2:47809 (global B/IP address of NAT B),				
	203.3.3.3:47809 (global B/IP address of NAT C)				
B/IP Address Net 2	192.168.1.10:47808				
BDT Net 2	192.168.1.10:47808 (self)				
BR2 - BBMD/Router Configu Global IP Address					
B/IP Address Net 1	237.2.2.2:47809 (global B/IP address of NAT B) 192.168.1.10:47809				
BDT Net 1	237.2.2.2:47809 (global B/IP address of NAT B, self),				
BD1 Net 1	201.1.1.1:47809 (global B/IP of NAT A),				
	203.3.3:47809 (global B/IP of NAT C)				
B/IP Address Net 3	192.168.1.10:47808				
BDT Net 3	192.168.1.10:47808 (self)				
	BR3 – BBMD/Router Configuration				
Global IP Address	203.3.3.3:47809 (global B/IP address of NAT C)				
B/IP Address Net 1	192.168.20.10:47809				
BDT Net 1	203.3.3.3:47809 (global B/IP address of NAT C, self),				
	201.1.1.1:47809 (global B/IP address of NAT A), 237.2.2:47809 (global B/IP address of NAT B)				
B/IP Address Net 4	192.168.20.10:47808				
BDT Net 4	192.168.20.10:47808 (self),				
DD1 Net 4	192.168.21.10:47808 (B/IP address of BBMD B1)				
B1-BBMD Configuration					
B/IP Address	192.168.21.10:47808				
BDT Net 4	192.168.21.10:47808 (self),				
	192.168.20.10:47808 (B/IP address of BBMD BR3)				

The broadcast distribution masks in the above BDT configurations are 255.255.255.255, indicating two-hop broadcast distribution.

# [Add a new entry to History of Revisions, p. 688]

(This History of Revisions is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard.)

#### HISTORY OF REVISIONS

Protocol		Summary of Changes to the Standard	
Version	Revision		
1	9	<ul> <li>Addendum o to ANSI/ASHRAE 135-2008</li> <li>Approved by the ASHRAE Standards Committee June 20, 2009; by the ASHRAE Board of Directors June 24, 2009; and by the American National Standards Institute June 25, 2009.</li> <li>1. Accommodate remote operator access and NAT in Annex J BACnet/IP.</li> </ul>	

© 2009, American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc. (www.ashrae.org). For personal use only. Additional reproduction, distribution, or transmission in either print or digital form is not permitted without ASHRAE's prior written permission.

#### POLICY STATEMENT DEFINING ASHRAE'S CONCERN FOR THE ENVIRONMENTAL IMPACT OF ITS ACTIVITIES

ASHRAE is concerned with the impact of its members' activities on both the indoor and outdoor environment. ASHRAE's members will strive to minimize any possible deleterious effect on the indoor and outdoor environment of the systems and components in their responsibility while maximizing the beneficial effects these systems provide, consistent with accepted standards and the practical state of the art.

ASHRAE's short-range goal is to ensure that the systems and components within its scope do not impact the indoor and outdoor environment to a greater extent than specified by the standards and guidelines as established by itself and other responsible bodies.

As an ongoing goal, ASHRAE will, through its Standards Committee and extensive technical committee structure, continue to generate up-to-date standards and guidelines where appropriate and adopt, recommend, and promote those new and revised standards developed by other responsible organizations.

Through its *Handbook*, appropriate chapters will contain up-to-date standards and design considerations as the material is systematically revised.

ASHRAE will take the lead with respect to dissemination of environmental information of its primary interest and will seek out and disseminate information from other responsible organizations that is pertinent, as guides to updating standards and guidelines.

The effects of the design and selection of equipment and systems will be considered within the scope of the system's intended use and expected misuse. The disposal of hazardous materials, if any, will also be considered.

ASHRAE's primary concern for environmental impact will be at the site where equipment within ASHRAE's scope operates. However, energy source selection and the possible environmental impact due to the energy source and energy transportation will be considered where possible. Recommendations concerning energy source selection should be made by its members.